



March 05, 2015

Invitation for Bid GSA-019-15
70-TON CHILLER REPLACEMENT

AMENDMENT #1

1. Amend to change "Bid Opening" date from March 9, 2015 at 10:00am to now read **March 16, 2015 at 10:00am**
2. Amend to change on bottom of page 2 "ACKNOWLEDGEMENT RECEIPT FORM" the following:

From:

Any questions and concerns in regards to this bid must be submitted by via facsimile no later than _____ before the close of business.

To now read:

Any questions and concerns in regards to this bid must be submitted by facsimile no later than **March 11, 2015** before the close of business.

3. Amend to change on page 28 under "SPECIFICATIONS" the following:

From:

Supply and Installation of NEW 70-Ton Chiller Air Cooled.

Must include the following

Electrical upgrade for the chilled water pump disconnect switches
Chemical Feeder to connect to CHW System.

Replacement of (2) existing pumps (ref: Centrifugal Series e-1510
2.5BB. Base mounted Volts 208 or 230, cycle 60, phase 3, RPM 1800,
HP 7.5, flow 240 gpm). and other appurtenances if required to include
Valves, thermometer, pressure gauge and thermostat, etc.

To now read:

Supply and Installation of NEW 70-Ton Chiller Air Cooled.

Must include the following

Enclosed Chiller Unit

Outdoor application

Electrical upgrade for the chilled water pump disconnect switches
Chemical Feeder to connect to CHW System.

Replacement of (2) existing pumps (ref: Centrifugal Series e-1510
2.5BB. Base mounted Volts 208 or 230, cycle 60, phase 3, RPM 1800,
HP 7.5, flow 240 gpm) and other appurtenances if required to include
Valves, thermometer, pressure gauge and thermostat, etc.

All others remains unchanged.


CLAUDIA S. ACFALLE
Chief Procurement Officer