

JOSHUA F. TENORIO
LIEUTENANT GOVERNOR

(SIGUNDO MAGA'HAGA)

DEPARTMENT OF ADMINISTRATION

GENERAL SERVICES AGENCY

AHENSIAN SETBISION HINIRAT 148 ROUTE 1 SOUTH MARINE CORPS DRIVE, PITI, GU 96915 TELEPHONE: (671) 475-1707/1708 FAX: (671) 472-4217/1727

EMAIL: GSAPROCUREMENT@GSADOA.GUAM.GOV
WEBSITE: WWW.GSA.DOA.GUAM.GOV



DEPUTY DIRECTOR

(SIGUNDO DIREKTOT)

May 28, 2021

Invitation For Bid GSA-023-21

Repair and Maintenance of Northern Region Recreational Swimming Pool, Dededo Sports
Complex

Question(s) and Concern(s) received from Total Chemical Resources Inc. on May 26, 2021

Further clarification to response on May 24, 2021.

Question: Filters – If filters are obsolete, can we offer replacement filters? Response: Yes, filters must be replaced by successful bidder.

1.) Please clarify if we are to replace:

- a. Only Internal Components, (Silica Sand and Laterals)? Or
- b. Internal and External Filters (3 each units), Entire Replacement of Filtering system, Filter Housing and Filter Media?

Response: Yes, the filtering system includes the filter housing and filter media and are all part of the filtering system that must be replaced by the successful bidder.

Claudia S. Acfalle Chief Procurement Officer

Please Print	
Acknowledgement	Copy (Re-Fax to G5A)
Received By:	
Date:	
Company Name:	
Fax to: 475-1727 or	472-4217
Email to: gsaprocur	ement@gsadoa.guam.gov