



LOURDES A. LEON GUERRERO
GOVERNOR (MAGA'HAGA)

JOSHUA F. TENORIO
LIEUTENANT GOVERNOR
(SIGUNDO MAGA'HAGA)

DEPARTMENT OF ADMINISTRATION

GENERAL SERVICES AGENCY

AHENSIAH SETBISION HINIRAT
148 ROUTE 1 SOUTH MARINE CORPS DRIVE, PITI, GU 96915
TELEPHONE: (671) 475-1707/1708
FAX: (671) 472-4217/1727
EMAIL: GSAPROUREMENT@GSADQA.GUAM.GOV
WEBSITE: WWW.GSA.DOA.GUAM.GOV



EDWARD M. BIRN
DIRECTOR (DIREKTOT)

BERNADINE C. GINES
DEPUTY DIRECTOR
(SIGUNDO DIREKTOT)

April 28, 2022

Invitation For Bid GSA-020-22 Camera System Upgrade and Replace Server System

Questions and Concerns received from G4S on March 25, 2022

Question 1:

Site Maps/Layouts with existing camera locations, junction boxes, conduit runs, building names, building measurements, so we can properly estimate wire and or conduit runs.

Response:

Refer to Amendment #3 for layout(s). For the security of the youth residing in DYA, DYA does not possess the layouts with measurements of all the conduit locations.

Question 2:

Please provide information on the area/s where the conduits are to be replaced or repaired and splice boxes located on each building.

Response:

A second site visit has been scheduled for clarification on exact locations where the conduits will need to be replaced. Refer to Amendment #3

Question 3:

We request a second site visit if the building measurements cannot be supplied.

Response:

A second has been scheduled, refer to Amendment #3.

Question 4:

Please provide the locations of all CCTV POE switches.

Response:

Superintendent's office, D-unit, E-unit, Liheng Famagu'on (LF), and F-unit.

Question 5:

Please clarify the number of hard drives and/or the minimum storage capacity that is required.

Response:

At least one month of footage to be stored.

Question 6:

Please extend the new RFI if there is a second site assessment.

Response:

Refer to Amendment #3

Question 7:

We would like to request a two-week extension.

Response:

Refer to Amendment #3

Question 8:

What is the estimate/budget for this project?

Response:

We do not provide the estimated budget cost for GSA-020-22

Question 9:

Please supply model number/s of the 6 Trendnet cameras that DYA has on hand and their NDAA compliance certifications. NON-NDAA Compliant equipment cannot be incorporated into an NDAA compliant system.

Response:

Model No. 71093111085. Please see attached pictures.

No NDAA certifications are on file as the 6 cameras were from a previous installation under a federal grant prior to the NDAA 2019 Act.

Question 10:

Is this project Federally funded?

Response:

Yes, funding is under the FY 2019 Prison Rape Elimination Act (PREA)

Question 11:

Who will be providing the Static IP?

Response: OTECH will provide the Static IP

Question 12:

What port will we be using to connect to the governments network?

Response:

Vendor awarded will work with OTECH to securely configure the respective network.

Question 13:

Who will be programming and configuring the government network?

Response:

Vendor awarded will work with OTECH to securely program and configure the respective network.

Question 14:

There are certain cameras at the facility without instructions on what to do with them. Please identify them and indicate if they will be removed, replaced, both or incorporated into the upgraded system. Note that any and/or all existing cameras to be added to the upgraded cctv system MUST be NDAA compliant.

Response:

Existing cameras must be incorporated into the upgrade system

Question 15:

Will the camera located outside F building be replaced?

Response:

No, this camera will not be replaced.

Question 16:

Are the cameras located in the Gym to be replaced?

Response:

No, they will not be replaced.

Question 17:

There were two exterior cameras located in the Intake Building. Are these cameras to be replaced?

Response:

Yes, these cameras will be replaced.

Questions and Concerns received from G4S on March 4, 2022

Question 1

Request for a site assessment.

Response:

Refer to Amendment #3

Question 2

Request for an additional RFI period after the site assessment.

Response:

Refer to Amendment #3

Question 3

Request for two weeks extension on the bid submittal deadline.

Response:

Refer to Amendment #3

Question 4

Please clarify the Governments need for assistance to purchase a Class 2, three quarter ton pickup truck as specified on IFB page 37.

Response:

Refer to Amendment #3

Question 5

Who will supply the internet connection for remote viewing capabilities and what will that connection speed be?

Response:

DYA will provide the internet access for remote viewing. This must be external to the government network.

Question 6

What is the funding source for this IFB?

Response: see response to question #10 received on March 25th

Question 7

What is the budgeted amount for this IFB?

Response: see response to question #8 received on March 25th

Question 8

What are the minimum baseline specs required for the 20 Dome and 1 PTZ camera/s?

Response:

Refer to Amendment #3

Question 9

Are the cameras for indoor or outdoor use?

Response:

DYA requires seventeen indoor cameras and three outdoor cameras.

Questions and Concerns received from Megabyte on March 4, 2022

Question 1:

Is OTECH currently managing DYA's network?

Response:

Yes. OTECH is managing DYA's network.

Question 2:

If so, will they allow access for remote viewing for the new surveillance server?

Response:

Yes. OTECH will allow for remote viewing. Vendor must work with OTECH to provide a secure connection.

Question 3:

Which staff member of DYA requires remote viewing?

Response:

The remote viewing will be accessed from the Building "A" Directors Office.

Question 4:

Is remote viewing, either on a cell phone or a laptop offsite, within the correctional institutional codes?

Response:


Yes, remote viewing is allowed at the Department of Youth Affairs.

Question 5:

With consideration of 200.216 Prohibition on certain telecommunications and video surveillance and equipment, is it within these guidelines to install the Trendnet cameras DYA currently has on hand as they are affiliated with Hikvision?

Response:

DYA purchased the cameras with federal grant prior to the new policy. No future purchases shall be made but the cameras that were previously purchased may be installed.


CLAUDIA S. ACFALLE
Chief Procurement Officer

Please Print

Acknowledgement Copy (Re-Fax to GSA)

Received By: _____

Date: _____

Company Name: _____

Fax to: 475-1727 or 472-4217

Email to: gsaprocmnt@gsadog.guam.gov