



EDWARD M. BIRN
Director (Direktat)

BERNADINE C. GINES
Deputy Director (Sigundo Direktat)

DEPARTMENT OF ADMINISTRATION

DIPATTAMENTON ATMENESTRASION

DIRECTOR'S OFFICE

(Ufisinan Direktat)

Telephone (Telifon): (671) 475-1101/1250



LOURDES A. LEON GUERRERO
Governor (Maga'håga)

JOSHUA F. TENORIO
Lt. Governor (Sigundo Maga'låhi)

May 3, 2022

To: All Bidders on GSA-RFP 001-22

A request to clarify amendment #1 was made.

Inquiry 1. In the amendment it does not state whether the government would be requiring painting of the newly replaced butler walls with poxy paint. Is that required? We believe that it should be due to the fact that it close to the ocean and exposed to the salt-laden environment.

GSA Response: Yes, painting of the newly replaced butler building walls with poxy paint would be responsible.

Inquiry 2. Is this proposal to be divided into two different Phases? Phase one for the building hardening and the other for Energy Conservation and Efficiency Retrofit?

GSA Response: To clarify, Phase One is for the replacement of deteriorating butler walls, support frame and steel structure, and Phase 2 is the energy conservation and retrofit.


ROBERT H. KONO

Please Print

Acknowledgement Copy (Re-Fax to GSA)

Received By: _____

Date: _____

Company Name: _____

Fax to: 475-1727 or 472-4217

Email to: gsaprocurment@gsadoa.guam.gov