



**DEPARTMENT OF
ADMINISTRATION**
DIPATTAMENTON ATMENESTRASION
GENERAL SERVICES AGENCY
(Ahension Setbision Hinirat)
Telephone (Telifon): (671) 475-1705/1706



September 18, 2025

Invitation For Bid
GSA-079-25
Removed and Replace Exterior Lights for the Village of Sinajana

Questions and Concerns received from Polyphase System Inc. on September 12, 2025.

1. Kindly Provide the technical specification for the existing poles, including

- 1.1 Material composition,
- 1.2 Height,
- 1.3 Top and bottom diameters,
- 1.4 Wall thickness,
- 1.5 Rated wind load capacity,
- 1.6 Foundation details.

This information is necessary to assess the poles' load-bearing capacity and verify whether they can safely support the combined wind load and weight of three (3) 1500W solar-powered LED light fixtures per pole.

Response:

- 1.1 Galvalvanized Metal**
- 1.2 16 feet High**
- 1.3 Top: 2 inches / Bottom: 4 inches diameter**
- 1.4 0.125 inches**
- 1.5 up to 150mph**
- 1.6 Pole secured to concrete foundation.**

Yes. These poles can safely support the combined wind load and weight of the requested lights.

2. Please provide the technical specifications for the following:

- 2.1 High bay type light fixture (8" round),
- 2.2 50w and 1500W Solar-powered LED Light Fixtures, and
- 2.3 Domestic preference requirements (whether BAA/BABA or not).

Response:

- 2.1 High Bay LED Lights: 150W / 100-277 Volts / 18,000 Lumens or higher / 5,000 K Color Temperature / 70CRI or higher**
- 2.2 Solar LED Light 1500W and Solar Panel 50W**
- 2.3 Solar LED Light 1500W and Solar Panel 50W**
- 2.4 This project is not regulated by BAA or BABA requirements.**

3. Kindly specify the source of funds allocated for this project.

Response:

Federal Emergency Management Agency Funds.

4. In view of the production and freight lead times associated with the lighting fixtures, we respectfully request that the required delivery date be extended from 30 days to 120 days upon receipt of purchase order.

Response:

Refer to Amendment #1.

5. We respectfully request that the submission dealing be extended from September 24, 2025, to October 3, 2025, to allow sufficient time for obtaining competitive vendor quotations and technical specification-compliant lighting fixtures.

Response:

Refer to Amendment #1.

Please Note: Follow up/Clarification to the Questions and Concerns responses dated 09/18/2025 must be submitted to the General Services Agency via email to gsaprocurement@gsadoa.guam.gov no later than 5pm, Friday, September 19, 2025.



Andriana Quitugua
Acting Chief Procurement Officer

Please Print
ACKNOWLEDGMENT COPY
Received By: _____
Date: _____
Company/Name: _____
Email To: gsaprocurement@gsadoa.guam.gov